



END VIEW W/O SUPPORTS

NEW LINE TANK

- 3) 4-1-04 PROOF TEST.
- 2) HYDRO @ 240 PSIG. MIN.
- NOTE: 1) SHIP LOOSE W/ (2) 1 5/16" x 32" LG. RIGID MAG. ANODES.

HEADS	.182" SA-455 2:1 S.E.	GS-36-500-H	REV. 9-15-04
	JOGGLE		DATE: 12-21-02
SHELL	.164" SA-414-G	FOR: HANSON STANDARD	
		HORIZ. HOT WATER TANK	
M.A.W.P. 160 PSIG. @ 210 °F		SURFACE AREA = 99 SQ. FT.	
ASME SECTION IV 2001 ADD. 2003		INSIDE: GLASS LINED	
X-RAY: RT-NO/H.L.W.		OUTSIDE: PRIME	
GALLONS: 500 WT. 815 LBS.		CAD-"B" UNDER "STD"-SERIES	
SERIAL NO.		BY: E.S. SCALE: 3/4"=12"	
		<b>ROY E. HANSON JR. MFG.</b>	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	