



- 3) 4-24-04 PROOF TEST.
- 2) HYDRO @ 240 PSIG.

NOTE: 1) SHIP LOOSE W/(1) 1 5/16" x 120" LG. FLEX. MAG. ANODE.

SHELL / HEADS	.245" SA-455 2:1 S.E.
	JOGGLE
	.200" SA-455
M.A.W.P.	160 PSIG. @ 210 °F
ASME. SECTION	IV 2004 ADD. 2005
X-RAY:	RT-NO / H.L.W.
GALLONS:	900
	WT. 1372 LBS.
SERIAL NO.	
N.B.	

GS-48-900-V	REV. 9-27-06
	DATE: 6-13-90
FOR: HANSON STANDARD	
VERT. HOT WATER TANK.	
SURFACE AREA = 136.7 SQ. FT.	
INSIDE: GLASS LINED	
OUTSIDE: PRIME	
CAD-"B" UNDER "STD"-SERIES	
LEG-ZONE 4-15 KM.	
BY: J.G.	SCALE: 3/4"=12"
ROY E. HANSON JR. MFG.	
1600 E. WASHINGTON BLVD.	
LOS ANGELES, CA 90021	